

Zertifikat Nr. Certificate No.
 R 50225724

 Blatt Page
 0001

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Ausstellungsdatum	Date of Issue
C.B.J	ZKR3-KIS- 13603135 001	06.04.2012	(day/mo/yr)

Genehmigungsinhaber License Holder
 Dong-A Electric Device Co., Ltd.
 38, Sinpyeong-dong, Saha-gu
 Busan 604-030
 Rep. of Korea

Fertigungsstätte Manufacturing Plant
 Dong-A Electric Device Co., Ltd.
 38, Sinpyeong-dong, Saha-gu
 Busan 604-030
 Rep. of Korea

Prüfzeichen Test Mark

 Geprüft nach Tested acc. to
 EN 60947-2:2006

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)
Lizenzentgelte - Einheit
License Fee - Unit
Circuit Breaker Moulded Case Circuit Breaker

Type Designations	: DB104Cb (DBwxyz)	6
w stands for	: Frame Designation (10, 6, 5, 3)	
x stands for	: Number of Poles (2, 3, 4)	
y stands for	: SC Capacity (F, C, S, H)	
z stands for	: Optional Code (b, none)	

Rated Operational Voltage	: 460V
Rated Frequency	: 50/60Hz
Rated Current	(w = 10) 15, 20, 30, 40, 50, 60, 75, 100A
	(w = 6) 15, 20, 30, 40, 50, 60A
	(w = 5) 15, 20, 30, 40, 50A
	(w = 3) 15, 20, 30A

Rated Insulation Voltage	: 690V
Rated Impulse Voltage	: 6kV
Utilization Category	: A
Pollution Degree	: 3
Reference Temperature	: 40°C
Suitability for Insulation:	Yes

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

 TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
 Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
 Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle

